

SECTION 6

6.37 SERVICE LINES:

Service lines shall be of the size, which is adequate to supply the requirements of the property being served. The minimum size line shall be 3/4 inch. The only acceptable materials for a service line are seamless copper tube, type K (soft) and ductile iron pipe. Service lines shall be of the same type material from beginning to end, unless the appropriate insulator is installed at the junctions of the dissimilar metals. See 3.09, MS-1 and Sheets 46 and 48 of the Standard Drawings.